

Table 1: Reactor Status in Japan (as of 19 January 2013)

Reactor	Date of latest power generation	Number of shutdown months	Number of shutdown years	Notes
Fukushima-Daini-1	11/03/11	22	1.8	Outage (In Cold shutdown since 14 March 2011)
Fukushima-Daini-2	11/03/11	22	1.8	Outage (In Cold shutdown since 14 March 2011)
Fukushima-Daini-3	11/03/11	22	1.8	Outage (In Cold shutdown since 12 March 2011)
Fukushima-Daini-4	11/03/11	22	1.8	Outage (In Cold shutdown since 15 March 2011)
Fukushima-Daiichi-5	03/01/11	24	2.0	Outage for Periodic inspection (In Cold shutdown since 20 March 2011)
Fukushima-Daiichi-6	14/08/10	29	2.4	Outage for Periodic inspection (In Cold shutdown since 20 March 2011)
Genkai-1	01/12/11	13	1.1	
Genkai-2	29/01/11	24	2.0	
Genkai-3	11/12/10	25	2.1	
Genkai-4	25/12/11	13	1.1	
Hamaoka-3	29/11/10	26	2.2	Shut down on government request of 6 May 2011
Hamaoka-4	13/05/11	20	1.7	Shut down on government request of 6 May 2011
Hamaoka-5	14/05/11	20	1.7	Shut down on government request of 6 May 2011
Higashi Dori 1	06/02/11	23	1.9	
Ikata-1	04/09/11	16	1.3	
Ikata-2	13/01/12	12	1.1	
Ikata-3	29/04/11	21	1.8	
Kashiwazaki Kariwa-1	06/08/11	17	1.4	
Kashiwazaki Kariwa-2	16/07/07	66	5.5	Reactors shut down since July 2007 Earthquake
Kashiwazaki Kariwa-3	16/07/07	66	5.5	Reactors shut down since July 2007 Earthquake
Kashiwazaki Kariwa-4	16/07/07	66	5.5	Reactors shut down since July 2007 Earthquake
Kashiwazaki Kariwa-5	25/01/12	12	1.0	
Kashiwazaki Kariwa-6	26/03/12	10	0.8	
Kashiwazaki Kariwa-7	23/08/11	17	1.4	
Mihama-1	24/11/10	26	2.2	
Mihama-2	18/12/11	13	1.1	
Mihama-3	14/05/11	20	1.7	
Monju	08/12/95	205	17.1	Monju was shut down on 8 December 1995 following a sodium fire. However, it was at 40% power when the accident happened and (likely) not generating power. Restart attempts have failed so far.
Ohi-1	10/12/10	25	2.1	
Ohi-2	16/12/11	13	1.1	
Ohi-3	in operation			Restarted on 5 July 2012
Ohi-4	in operation			Restarted on 21 July 2012
Onagawa-1	11/03/11	22	1.8	Automatic shutdown on 11 March 2011 - JAIF says Outage for Periodic inspection (10 September 2011-); according to JAIF, Monthly Data, no electrical production April-September 2011
Onagawa-2	06/11/10	26	2.2	
Onagawa-3	11/03/11	22	1.8	Automatic shutdown on 11 March 2011 - JAIF says Outage for Periodic inspection (10 September 2011-); according to JAIF, Monthly Data, no electrical production April-September 2011
Sendai-1	10/05/11	20	1.7	
Sendai-2	01/09/11	16	1.8	
Shika-1	01/03/11	22	1.8	JAIF says Outage for equipment replacement (1 March 2011 but Outage for Periodic inspection (8 October 2011 -)); according to JAIF, Monthly Data, no electrical production April-September 2011
Shika-2	11/03/11	22	1.8	
Shimane-1	08/11/10	26	2.2	
Shimane-2	27/01/10	36	3.0	
Takahama-1	10/01/11	24	2.0	
Takahama-2	25/11/11	14	1.2	
Takahama-3	20/02/12	11	0.9	
Takahama-4	21/07/11	18	1.5	
Tokai-2	11/03/11	22	1.8	Automatic shutdown on 11 March 2011 - JAIF says Outage for Periodic inspection (21 May 2011 -); according to JAIF, Monthly Data, no electrical production April-May 2011
Tomari-1	22/04/11	21	1.8	
Tomari-2	26/08/11	17	1.4	
Tomari-3	05/05/12	8	0.7	
Tsuruga-1	26/01/11	24	2.0	
Tsuruga-2	29/08/11	17	1.4	
Total 51 Reactors		26	2.2	Average

maximum	17.1	5.5 years without Monju
minimum	0.7	

Sources

- For shutdown dates: JAIF - Japan Atomic Industrial Forum, Current Status of the Nuclear Power Plants in Japan - Stress Test and Restart Status - As of 3 September 2012, http://www.jaif.or.jp/english/news_images/pdf/ENGNEWS02_1347267232P.pdf — unless otherwise noted.
- For electricity production: JAIF, Operating Records of Nuclear Power Plants (Monthly Report) April-September 2011